# **NAMRON ZIGBEE SWITCH 400W**

09.ZG09SAP.04736








Important: Read All Instructions Prior to Installation

#### **Function introduction**



### **Product Data**

Input Voltage	Output Voltage	Output Current	Size(LxWxH)
100-240VAC	100-240VAC	1.5A max	45.5x45x20.3mm

Compatible Load Types				
Load Symbol	Load Type	Maximum Load	Remarks	
<b>→</b>	LED lamps with transformers	200W @ 220V 100W @ 110V	Due to variety of LED lamp designs, maximum number of LED lamps is further dependent on powher factor result when connected to switch.	
<del>-</del>	LED drivers	200W @ 220V 100W @ 110V	Maximum permitted number of drivers is 200W divided by driver nameplate power rating.	
-\\[C	Incandescent lighting, HV Halogen lamps	400W @ 220V 200W @ 110V		
	Low voltage halogen lighting with electronic transformers	200W @ 220V 100W @ 110V		

- ZigBee in-wall switch based on latest ZigBee 3.0 protocol
- 100-240VAC Wide Input and Output Voltage
- · Supports resistive loads and capacitive loads
- 1 Channel Output, Up to 400W
- Input and Output with Screw Terminals. Safe and Reliable
- Enables to control ON/OFF of connected load
- ZigBee end device that supports Touchlink commissioning
- Can directly pair to a compatible ZigBee remote via Touchlink without coordinator
- Supports self-forming zigbee network without coordinator and add other devices to the network
- Supports find and bind mode to bind a ZigBee remote
- Supports zigbee green power and can bind max. 20 zigbee green power remotes
- · Compatible with universal ZigBee gateway products
- Can be controlled by universal 8-230V input single wire push switch
- Mini Size, Easy to be Installed into a standard 86\*86mm wall box
- Radio Frequency: 2.4GHz • Waterproof grade: IP20

### Safety & Warnings

- · DO NOT install with power applied to device.
- DO NOT expose the device to moisture.

### ZigBee Clusters the device supports are as follows:

#### Input Clusters

0x0000: Basic 0x0003: Identify 0x0004: Groups 0x0005: Scenes 0x0006: On/off

0x0b05: Diagnostics **Output Clusters** 

0x0019: OTA


### Operation

- 1.Do wiring according to connection diagram correctly.
- 2. This ZigBee device is a wireless receiver that communicates with a variety of ZigBee compatible systems. This receiver receives and is controlled by wireless radio signals from the compatible ZigBee system.

#### 3. Zigbee Network Pairing through Coordinator or Hub (Added to a Zigbee Network)

Step 1: Remove the device from previous zigbee network if it has already been added to, otherwise pairing will fail. Please refer to the part "Factory Reset Manually".

Step 2: From your ZigBee Controller or hub interface, choose to add lighting device and enter Pairing mode as instructed by the controller.



#### 4. TouchLink to a Zigbee Remote Step 1: Method 1: Short press "Reset" button (or re-power on the device) 4 times to start Touchlink commissioning immediately, 180S timeout, Step 2: Bring the remote or touch repeat this step. panel within 10cm of the lighting Method 2: Re-power on the device. device, Touchlink 41-42-8-230V= Zigbee commissioning will start after < 10cm Step 3: Set the remote or touch Remote 15 minutes if it's not added to a panel into Touchlink commissioning, zigbee network, 165S timeout. LLNN please refer to corresponding -Or start immediately if it's remote or touch panel manual to already added to a network, learn how. 180S timeout. Once timeout, repeat this step. Step 4: There shall be indication on the remote for successful link and connected light will flash

Note: 1) Directly TouchLink (both not added to a ZigBee network), each device can link with 1 remote.


- 2) TouchLink after both added to a ZigBee network, each device can link with max. 30 remotes.
- 3) For Hue Bridge & Amazon Echo Plus, add remote and device to network first then TouchLink.
- 4) After TouchLink, the device can be controlled by the linked remotes.

## 5. Removed from a Zigbee Network through Coordinator or Hub Interface




From your ZigBee controller or hub interface, choose to delete or reset the lighting device as instructed. The connected light blinks 3 times to indicate successful reset.

### 6. Factory Reset Manually




### 7. Factory Reset through a Zigbee Remote (Touch Reset)

**Note**: Make sure the device already added to a network, the remote added to the same one or not added to any network.




#### 8. Find and Bind Mode

Note: Make sure the device and remote already added to the same zigbee network.




#### 9. Learning to a Zigbee Green Power Remote




Note: Each device can learn to max. 20 zigbee green power remote.

### 10. Delete Learning to a Zigbee Green Power Remote



## 11. Setup a Zigbee Network & Add Other Devices to the Network (No Coordinator Required)



**Step 2**: Set another device or remote or touch panel into network pairing mode and pair to the network, refer to their manuals.

Step 3: Pair more devices and remotes to the network as you would like, refer to their manuals.

**Step 4**: Bind the added devices and remotes through Touchlink so that the devices can be controlled by the remotes, refer to their manuals.

Note: 1) Each added device can link and be controlled by max. 30 added remotes.


2) Each added remote can link and control max. 30 added devices.

#### 12. OTA


The device supports firmware updating through OTA, and will acquire new firmware from zigbee controller or hub every 10 minutes automatically.

### Wiring Diagram

(1)With Push



(2)With Push LV



Importer: Namron AS Nedre kalbakkvei 88B 1081 Olso Norway

Made in China